

**DISTRICT OF COLUMBIA
WATER AND SEWER AUTHORITY**



"SERVING THE PUBLIC - PROTECTING THE ENVIRONMENT"

**SUPPLEMENTAL
STANDARD SPECIFICATIONS**

November 2018

THIS PAGE IS INTENTIONALLY LEFT BLANK

AUTHORIZATION FORM

Supplemental Standard Specifications LOG OF REVISIONS	
Issue Date	Brief Description of Revision
November 2018	Section 32 92 23 SUP – Sodding: Added Supplemental Specification which includes: <ul style="list-style-type: none"> • Adding Article 2.5. Section 33 12 16 SUP – Tapping Sleeves and Valves: Added Supplemental Specification which includes: <ul style="list-style-type: none"> • Replacing Paragraphs 1.3 C and 3.2 F. • Deleting Paragraph 2.1 C. Section 33 29 50 SUP – Temporary Water Piping: Added Supplemental Specification which includes: <ul style="list-style-type: none"> • Replacing Paragraph 3.6 E.

These Supplemental Standard Specifications are authorized by:



 Craig A. Fricke, P.E., Director,
 Department of Engineering and Technical Services
 DC Water

31-27-18

 Date

THIS PAGE IS INTENTIONALLY LEFT BLANK

SECTION 32 92 23 SUP

SODDING

The following modifications are made to Standard Specification Section 32 92 23 - Sodding.

Part 2. – Add Article 2.5 as follows:

2.5 BIOSOLIDS:

- A. Biosolids may be mixed with top soil to achieve the required properties specified in Article 2.1 above.
- B. Biosolid shall have the following properties:
 - 1. Classification – Class A EQ.
 - 2. Minimum plant available nitrogen – 6 lbs per wet ton.
 - 3. pH Range – 6.5 to 8.5.
 - 4. Organic Matter Range – 50 to 65 percent by dry weight.
- C. Approved biosolids:
 - 1. Bloom by DC Water.
 - 2. Or equal.

~ END OF SECTION 32 92 23 SUP ~

THIS PAGE IS INTENTIONALLY LEFT BLANK

SECTION 33 12 16 SUP
TAPPING SLEEVES AND VALVES

The following modifications are made to Standard Specification Section 33 12 19 – Tapping Sleeves and Valves.

1.3 C – Replace paragraph 1.3 C with the following:

Section 33 05 02: Water Utility Distribution Piping – Ductile Iron Pipe.

2.1 C - Delete paragraph 2.1 C.

3.2 F – Replace paragraph 3.2 F with the following:

Restrain all joints using an approved restrained jointing system in accordance with Section 33 05 02 – Water Utility Distribution Piping – Ductile Iron Pipe.

~ **END OF SECTION 33 12 16 SUP** ~

THIS PAGE IS INTENTIONALLY LEFT BLANK

SECTION 33 29 50 SUP
TEMPORARY WATER PIPING

The following modifications are made to Standard Specification Section 33 29 50 – Temporary Water Piping.

3.6 E - Replace paragraph 3.6 E with the following:

Notify DC Water prior to taking a hydrant out of service or placing it into service. This includes the initial installation of a hydrant. DC Water will install and remove the “HYDRANT OUT OF SERVICE” ring and make appropriate notifications.

~ **END OF SECTION 33 29 50 SUP** ~

THIS PAGE IS INTENTIONALLY LEFT BLANK