



DC Water
Department of Water Services
Drinking Water Division Compliance Program

3900 Donaldson Pl, NW., Washington, D.C. 20016
202 364-3144 crossconnection@dcwater.com

DC Water does not provide backflow preventer inspection tags. Inspectors must provide their own. A new inspection tag must be attached to the backflow preventer after each inspection. Inspection tags may vary in format and style.

All inspection tags must have the following fields:

- Inspection date
- Manufacturer
- Serial number
- Type (i.e. DCVA)
- Size
- Connected to (i.e. boiler system)
- Inspection company name
- Inspection company address
- Inspection company phone
- Inspector's initials
- Certification number
- Pass or fail check boxes

Example of inspection tag with required fields

